



ELECTRICAL SAFETY PERMITS

PULLED IN ORANGEBURG COUNTY

AT TIME OF INSPECTION THE FOLLOWING ITEMS NEED TO BE COMPLETED

- ❖ Permit must be posted in a visible location at property entrance.
- ❖ 911 Addressing must be on site in the form of 4" high numbers that are visible from the street that the residence is on.
- ❖ Smoke detectors shall be in place
 - Manufactured homes must have smoke detectors mounted where originally mounted at the factory. (Min. of 2 – 1 at each end outside of bedroom)
 - Stick built homes must have smoke detectors in each bedroom and in the room adjacent to bedrooms as well as each level.
 - If gas equipment is utilized combination carbon monoxide/smoke detectors must be used.
- ❖ Access must be provided to interior panel as well as any areas that the feeder cables are routed thru.
- ❖ Ground rods must be visible at the time of inspection.
- ❖ All clamps or strapping must be completed upon our arrival. Service entrance cables as well as mast poles must be strapped a minimum of 12" below soffit penetration, 12" above meter base, and no greater than 30" in between.
- ❖ Work in the Aiken electric areas requires a weather head to be provided on both service entrance cables and mast poles.
- ❖ Meter bases in the S.C.E.& G. area's do not permit the use of "Ringed Meter Bases"
- ❖ A permanent Heat source must be present. (Non-vented gas fired heaters cannot be used as sole source of heat)
- ❖ Home must be water tight with all emergency egress exits accessible.