



GAS PERMITS PULLED IN ORANGEBURG COUNTY

PRESSURE TESTING

All gas pressure gauges used for testing Residential/Commercial installations shall be a maximum of 30 P.S.I.

When testing gas systems up to 5 psi; test pressure applied **must be exactly 10 psi** of air pressure.

(Temperature change will be taken into consideration)

BONDING OF GAS PIPING

Gas piping must be electrically bonded by any of the means below.

1. Bonded to the electrical service grounding electrode system
(No Separate grounding rod allowed for bonding purposes)
2. Appliances that are electrically connected.

All CSST piping must be bonded back to the electrical service grounding electrode system

(No Separate grounding rod allowed for bonding purposes)

VISUAL INSPECTION

Any gas piping installed entering the inside of a structure must be inspected for shut off valves and sediment traps. We will require access inside the structure to visually inspect the gas piping. There will be a \$45 re-inspection fee if structure is not accessible.